




U imp 6 kV

Ie 20 A

Iq 3 kA

Max. zul. Motorleistung / Max. Motor Performance / Max. Potencia admisible del Motor / Puissance max. du Moteur / Pot. max. ammissibile dei motori



	EN 60947 – 4 - 1
50.. ..60 Hz	1~
120 V AC3	2 kW
250 V AC3	4 kW




DRAUFSICHT / TOP VIEW / VISTA SUPERIOR / VUE SUPERIEURE / VISTA DALL'ALTO
 SCHALTBILD / WIRING DIAGRAM / ESQUEMA DE CONEXION / SCHEMA DE RACCORDAMENTO / SCHEMA ELETTRICO

Druckdifferenz optional
 Pressure differential optional
 Diferencial de presión opcional
 Différentiel de pression optionelle
 Pressione differenziale opzionale



Motor
 Moteur
 Motore

Netz
 Mains
 Red
 Alimentation
 Alimentazione




Einschaltdruck
 Cut-in pressure
 Presión de disparo inferior
 Pression de d'enclenchement
 Pressione di attacco

1.8 Nm
 Drehmoment
 Tightening torque
 Par de giro
 Couple
 Momento torcente

Motor
 Moteur
 Motore

Netz
 Mains
 Red
 Alimentation
 Alimentazione

DRUCKDIAGRAMME / PRESSURE DIAGRAMS / DIAGRAMAS DE REGULACION / DIAGRAMMES DE REGLAGE / DIAGRAMMI TARATURE



Einschaltdruck
 Cut-in pressure
 Presión de disparo inferior
 Pression de d'enclenchement
 Pressione di attacco

Ausschaltdruck po (bar)
 Cut-out pressure
 Presión de disparo superior
 Pression déclenchement
 Pressione di distacco

Einbau und Anschluß nur durch Fachkraft; nach Anbringung von Zubehör Funktionsüberprüfung durch Elektrofachkraft erforderlich

Installation and assembly of electrical equipment shall be carried out by qualified personnel only
 Instalación y ensamblaje de equipos eléctricos deberán ser efectuados solamente por personal cualificado

L'installation et raccordement des appareils doit être effectué par du personnel qualifié

L'installazione e l'assemblaggio delle parti elettriche vanno eseguite esclusivamente da personale qualificato

APPROBATIONEN / APPROVALS / APROBACIONES / APPROBATIONS / APPROVAZIONI



100% Einschaltdauer (uninterrupted duty)

Kurzschlußeinrichtung / Short-circuit protection / Protección contra corto circuito


Protection contre court-circuit/ Protezione contro corto circuito

Type	Koordination Type " 1 "		Koordination Type " 2 "	
Tipo	Co-ordination Type " 1 "		Co-ordination Type " 2 "	
	Coordinación Tipo " 1 "		Coordinación Tipo " 2 "	
	Coordination Type " 1 "		Coordination Type " 2 "	
	Coordinamento Tipo " 1 "		Coordinamento Tipo " 2 "	
Sicherung gL	manuell	pneumatisch	manuell	pneumatisch
Fuse (slow)			35A	50A
Fusible (retardado)				
Fusible (retardé)				
Fusibile (ritardato)				

Schutz / Degree of Protection / Grado de Protección / Degré de Protection / Grado di Protezione

IP 44

Einbaulage berücksichtigen / Mounting position must be observed / Respetar posición de montaje
 Observer position de montage / Rispettare posizione montaggio



0.0800.0343 02.11.2005



Condor Pressure Control GmbH

Warendorfer Straße 47 – 51
 D-59320 Ennigerloh

Telefon: +49 (0) 25 87 / 89 – 0
 Telefax: +49 (0) 25 87 / 89 - 140

info@condor-cpc.com
 www.condor-cpc.com